



Bartow County Fire Dept.
Gary Garland, Fire Marshal
 5435 Highway 20 N.E.
 Cartersville, GA 30121

Office: 678-721-5495
Email: garlandg@bartowga.org

New Business Life Safety Checklist

Name of Facility _____ Date _____

Address _____

Emergency Contact Name and Phone # _____

	Yes	No	N/A	Remarks Section
Street Address Posted (4" min.)				
Fire walls or partitions have no penetrations				
Exit are Marked & Signs Lit				
Emergency Lighting Operable				
Exit Doors are Clear & Unlocked				
Electrical Room Clear & Accessible				
No Extension Cords				
All electrical switches and outlets are covered				
No open empty spaces in panel box				
Compressed gas cylinders are secured				
Portable Fire Extinguishers Maintained & Tagged (min. 5lb. ABC)(serviced yearly)				
Gas fired water heater has min. of 3' clearance all around from combustibles				
Storage- not blocking exits, panel boxes, etc.				
Sprinkler System Maintained & Tagged (serviced yearly)				
Hood System Maintained & Tagged – (Every 6 Months)				

Fulfilling the requirements of this form does not ensure that a business license will be issued. This form is meant to help new business owners with the Bartow County Fire Marshals' Business License inspection process and is not an all inclusive form.